

**SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No.: 1113

Dated: 21/07/2023

It is certified that an inspection team headed by **K.S. Patel, Assistant Engineer** from **Public Health Engineering**, Sub-Division- Dabhara, Dist.- Sakti (C.G) inspected **Chandahasini Vidyapeeth, Mirouni, Chandrapur, Dist- Sakti (C.G)** on 21/07/2023.....(date of inspection)

and found that **Chandahasini Vidyapeeth, Dabhara Road Mirouni, Chandrapur** has safe drinking water facilities

for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 21/01/2024.....


Assistant Engineer
Public Health Engineering
Dist. Jangsi-Champna C.G
Name :K.S.Patel

Designation : Assistant Engineer

Name & Address of the Office / Department: Public Health Engineering

Sub-Division- Dabhara,

Dist.- Sakti (C.G)

To

Chandahasini Vidyapeeth

Mirouni, Chandrapur, Dist- Sakti (C.G)

(Name & Address of the Institution)

कार्यालय सहायक अभियंता लोक स्वास्थ्य यांत्रिकी उपखण्ड डभरा
जिला-सक्ती (छ.ग.)

Email- aepbedbr@gmail.com

पत्र क्र. 1113 /स.अ./लो.स्वा.या.उपखण्ड/2023

डभरा, दिनांक 21.07.2023

प्रति,


प्रधान पाठक
चन्द्रहासिनी विद्यापीठ मिरौनी
जिला-सक्ती (छ.ग.)

विषय :- दिये गये वाटर सैम्पल का टेस्ट रिपोर्ट प्रदाय करने बाबत।

उपरोक्त विषयांतर्गत लेख है कि चन्द्रहासिनी विद्यापीठ मिरौनी जिला- सक्ती (छ.ग.) के अंतर्गत पेयजल प्रदाय स्रोत का जल नमूना परीक्षण हेतु इस कार्यालय को दिनांक 21.07.2023 को आपके द्वारा प्राप्त हुआ है।

जल का भौतिक एवं रासायनिक परीक्षण कर प्रतिवेदन सूचनार्थ एवं आवश्यक कार्यवाही हेतु आपकी ओर प्रेषित है।

संलग्न :- जल परीक्षण रिपोर्ट।


Assistant Engineer
Public Health & Engineering
लोक स्वास्थ्य यांत्रिकी उपखण्ड डभरा
जिला-सक्ती (छ.ग.)

OFFICE OF THE ASSISTANT ENGINEER PUBLIC HEALTH ENGINEERING SUB DIVISION-DABHARA


Water Test Report by Field Test Kit

Village:- Mirouni , Block - Dabhara, Distt.- Sakti (C.G.)

Details of Source & Locations :-

Date - 24.07.2023

S.No.	Village	Location	Source	RESULT											Remark
				Turbidity (N.T.U.)	PH (PH Scale)	Chlorides (as Cl) (mg/l)	Nitrates (as NO ₃) (mg/l)	Total Hardness (as CaCO ₃) (mg/l)	Iron (as Fe) (mg/l)	Flourides (as F) (mg/l)	Residual Chlorine	Phosphate	Total Alkalinity	Bacteriological Test (Positive/Negative)	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
1	Mirouni	Chandrasasini vidhyapeeth, Mirouni	P.P.	1.01	7.00	40.00	0.0	50	0.0	0.0	0.0	0.0	50.00	Negative	Water is potable


Chemist
P.H.E. Laboratory Dabhara
Dist.- Sakti (C.G.)


Assistant Engineer
Public Health Engineering
Distt. Janjati-Chemara
P.H.E. Sub-Division Dabhara
Dist. - Sakti (C.G.)